

LRB-2024-21

23/02045/FLL – Alterations and extension to dwellinghouse and formation of raised patio, Ochil Cottage, Main Street, Glenfarg, Perth, PH2 9NY

REPRESENTATIONS

Monday, 15 January 2024



Local Planner
Planning and Development
Perth and Kinross Council
Perth
PH1 5GD

Development Operations
The Bridge
Buchanan Gate Business Park
Cumbernauld Road
Steps
Glasgow
G33 6FB

Development Operations
Freephone Number - 0800 3890379
E-Mail - DevelopmentOperations@scottishwater.co.uk
www.scottishwater.co.uk



Dear Customer,

Ochil Cottage Main Street, Glenfarg, Perth, PH2 9NY
Planning Ref: 23/02043/FLL
Our Ref: DSCAS-0101497-8SQ
Proposal: Alterations and extension to dwellinghouse and formation of raised patio

Please quote our reference in all future correspondence

Audit of Proposal

Scottish Water has no objection to this planning application; however, the applicant should be aware that this does not confirm that the proposed development can currently be serviced and would advise the following:

For all extensions that increase the hard-standing area within the property boundary, you must look to limit an increase to your existing discharge rate and volume. Where possible we recommend that you consider alternative rainwater options. All reasonable attempts should be made to limit the flow.

No new connections will be permitted to the public infrastructure. The additional surface water will discharge to the existing private pipework within the site boundary.

Asset Impact Assessment

Scottish Water records indicate that there is live infrastructure in the proximity of your development area that may impact on existing Scottish Water assets.

- ▶ 20" trunk water main within the front of the site boundary

The applicant must identify any potential conflicts with Scottish Water assets and contact our Asset Impact Team via [our Customer Portal](#) for an appraisal of the proposals.

The applicant should be aware that any conflict with assets identified will be subject to restrictions on proximity of construction. Please note the disclaimer at the end of this response.

Written permission must be obtained before any works are started within the area of our apparatus

I trust the above is acceptable however if you require any further information regarding this matter please contact me on **0800 389 0379** or via the e-mail address below or at planningconsultations@scottishwater.co.uk.

Yours sincerely,

Angela Allison

Development Services Analyst

PlanningConsultations@scottishwater.co.uk

Scottish Water Disclaimer:

"It is important to note that the information on any such plan provided on Scottish Water's infrastructure, is for indicative purposes only and its accuracy cannot be relied upon. When the exact location and the nature of the infrastructure on the plan is a material requirement then you should undertake an appropriate site investigation to confirm its actual position in the ground and to determine if it is suitable for its intended purpose. By using the plan you agree that Scottish Water will not be liable for any loss, damage or costs caused by relying upon it or from carrying out any such site investigation."