

**LRB-2024-20**

**23/02046/FLL – Alterations to dwellinghouse, 41 Coltward  
Holding, Campmuir, Blairgowrie, PH13 9LN**

## **REPRESENTATIONS**



## Audit of Proposal

Good Afternoon

Scottish Water has no objection to this planning application; however, the applicant should be aware that this does not confirm that the proposed development can currently be serviced and would advise the following:

For all extensions that increase the hard-standing area within the property boundary, you must look to limit an increase to your existing discharge rate and volume. Where possible we recommend that you consider alternative rainwater options. All reasonable attempts should be made to limit the flow.

No new connections will be permitted to the public infrastructure. The additional surface water will discharge to the existing private pipework within the site boundary.

I trust the above is acceptable however if you require any further information regarding this matter please contact us on 0800 389 0379 or via the e-mail address below or at [planningconsultations@scottishwater.co.uk](mailto:planningconsultations@scottishwater.co.uk).

Ruth Kerr

Technical Analyst  
North Regional Team

Strategic Development  
Development Services  
Dedicated Freephone Helpline: 0800 389 0379

[DevelopmentOperations@scottishwater.co.uk](mailto:DevelopmentOperations@scottishwater.co.uk)

Scottish Water.

Trusted to serve Scotland.

----- Original Message -----

**From:** Local Planner <[developmentmanagement@pkc.gov.uk](mailto:developmentmanagement@pkc.gov.uk)>;

**Received:** Thu Dec 14 2023 10:25:03 GMT+0000 (Greenwich Mean Time)

**To:** <[planningconsultations@scottishwater.co.uk](mailto:planningconsultations@scottishwater.co.uk)>;

**Subject:** Planning Application Consultation Request for Application No 23/02046/FLL

\*\*EXTERNAL MAIL\*\* - Think Before You Click

